



Facility Name: All Seasons Cairns Gateway Resort

Facility Type: Resort

Facility Address: Cnr Anderson Rd and Bruce Highway, Cairns

**Phone: 07 4054 7700 – within Australia
+61 7 4054 7700 – International**

**Fax: 07 4054 7750 – within Australia
+61 7 4054 7750 – International**

Email: res@cairnsgatewayresort.com

Web: www.allseasons.com.au

**Room numbers: Two accessible rooms, with no interconnecting rooms.
Self contained with small kitchenette.**



All Seasons Cairns Gateway Resort

Note:

The resort accommodation bathroom and toilet are smaller than the required standard and is more suitable to a person with an ambulant disability or a person who needs a hobless shower. Guests with a mobility device may have issues with full bathroom access.

Parking:

There are two accessible parking bays provided for guests at the rear of the resort located outside the accessible rooms. If travelling by coach or taxi there is an accessible undercover set down area immediately in front of the reception.



Accessible car parking



Undercover drop off area

Entry into reception

Entry to reception is either up a ramp or set of 5 steps and then into reception. A set of double manual doors take you through to reception where you will be greeted by friendly and very helpful staff. The reception counter does not have a lowered section for wheel chairs but staff will assist guests if required. You will also find a convenience store within reception.



Reception desk



Convenience store within reception

Access to public areas

The resort has good wide paths that lead from the reception area to the resort pool and Pickled Frog Bar and Cafe. The pool will not be accessible to all guests as there is no accessible entry.



Pool and BBQ area



Bar and Cafe

Accommodation:

The accessible guest rooms are on level access with no steps or sills. The door handles are knob style with a clear opening width of 950mm. Door opening force is very light.

Room furniture can be moved to suit the guest's requirements; staff are more than happy to assist.

The accessible bed room has a queen bed and there is ample room to move around it or it can be moved easily to allow greater room to one side, in its current configuration the widest clear space is 1740mm. Under bed clearance is 100mm and the height to the top of bed is 540mm.

A desk is provided with a height of 750mm to the top of desk and a 715mm under clearance.



Level access into room



Queen bed



Kitchenette

Bathroom Facilities:

Entry into the shower and toilet is through a wide door with a clear width of 950mm. There is a small step up of 25mm, this may impact on some mobility devices.

The facility is a combined toilet and shower with a dimension of 1800mm long by 1795mm wide. The shower is hob less and has a dimension of 887mm wide by 500mm long (see floor plan below).

Horizontal grab rails only are fitted to the shower and are mounted 850mm from the floor to top of grab rail. No vertical rail is mounted at the shower rose. Knob style taps are fitted in the shower and sink.

The shower does not have a fold down seat, a portable shower seat/commode can be hired from Phoenix Medical and Prescription and delivered to the accommodation if required. Contact Phoenix on 4041 3629. There are horizontal and vertical grab rails fitted and a long lever flick mix tap.

The toilet is located 400mm from the side wall to the centre of the pan and 430mm from floor to top of seat. A small grab rail is fitted beside the toilet and is only suitable for ambulant disability. Clearance from front of the pan to the wall is 980mm.

There is no clearance under the sink for access by mobility devices. The sink has a top height of 880mm. The height from the floor to the base of the mirror is 1225mm.




Shower



Sink



Toilet grab rail configuration



General:

Staff are very friendly and will assist with baggage and ensuring you are comfortable during your stay. Assistance dogs are welcome and may stay in room.